

**SOX MONITOR
DOWNTIME**

Thermo Scientific
Model: 43i-HL
Serial Numbers:
1027444707

Date	Start Time	End Time	Duration	Reason	Action	Incinerator Operation
WORK ON THIS ANALYZER						
OUT OF CONTROL PERIODS						
SYSTEM RECALIBRATIONS						
OTHER ANALYZER WORK AFFECTING THIS ANALYZER						
8/11/2014	7:30 AM	7:37 AM	7	OTHER ANALYZER WORK DONE (Wet O2)	Manual Calibration	On Fuels
8/13/2014	7:10 AM	7:20 AM	10	OTHER ANALYZER WORK DONE (Wet O2)	Manual Calibration	On Hazardous Waste
9/22/2014	5:50 AM	7:02 AM	72	OTHER ANALYZER WORK DONE (Wet O2)	Manual Calibration	On Hazardous Waste
				Other		
UNRECORDED TIME (MISSING MINUTES)						
TOTAL MINUTES IN QUARTER:					132,480	
TOTAL OPERATING TIME OF SOURCE:					113,231	
TOTAL DOWNTIME OF CEM SYSTEM:					89	
CEM DOWNTIME DURING SOURCE OPERATING TIME:					89	
TOTAL OPERATING TIME OF SOURCE AND CEM TOGETHER:					113,142	
SYSTEM AVAILABILITY					99.9%	
		Cells with this format is not counted toward source operating time.				